

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

415 Knollcrest Drive, Suite 100, Redding, CA 96002

PUBLIC HEARING
concerning

Consideration of Renewal of Waste Discharge Requirements
(National Pollutant Discharge Elimination System Permit No. CA0081744),
for

**GRIZZLY LAKE RESORT IMPROVEMENT DISTRICT
DELLEKER WASTEWATER TREATMENT PLANT
PLUMAS COUNTY**

The Discharger owns and operates a wastewater collection, treatment, and disposal facility providing sewer service to homes and businesses in the District. The Facility treats up to 0.1 mgd of domestic wastewater, and consists of headworks, five ponds (two aerated), and chlorination/dechlorination facilities. From 1 November to 15 May, discharge to the Middle Fork of the Feather River (River) is allowed when receiving water flow is greater than 40 cfs. From 16 May to 31 October, or when river flow is less than 40 cfs, the wastewater is stored in the ponds. When discharge occurs, ultimate dilution of wastewater in the River is at least 260:1, and often much greater.

This Order requires the Discharger to develop and submit: 1) a Sludge Disposal Plan; 2) a Septage Receiving Study; 3) a study on appropriate electrical conductivity levels in the effluent; and 4) a Groundwater Monitoring Study.

The hearing on this matter scheduled for 26 October 2007 has been rescheduled to the Central Valley Regional Water Quality Control Board (Regional Board) meeting of 15/16 March 2007. The written comment period for this agenda item ended on 22 October 2006 and no more written comments will be accepted. Interested persons will have an opportunity to make oral comments at the 15/16 March 2007 meeting. Revisions made as a result of the comment period are shown in the Order in underline/strikeout. Documents relevant to this matter will be available by 26 February 2006 from the Regional Board's Internet website at <http://www.waterboards.ca.gov/centralvalley/tentative/>. After 26 February 2007, the proposed item and related documents may be inspected and copied at the Regional Board's office at 415 Knollcrest Drive, Suite 100, Redding, California, weekdays between 8:00 a.m. and 5:00 p.m. Anyone having questions regarding this issue should contact Ron Dykstra at (530) 224-4858, or Mary Randall at (530) 224-4860.

NOTICE OF PUBLIC HEARING
GRIZZLY LAKE RESORT IMPROVEMENT DISTRICT
DELLEKER WASTEWATER TREATMENT PLANT
PLUMAS COUNTY

-2-

A public hearing concerning this matter will be held during the Regional Board meeting, which is scheduled for:

DATE: 15/16 March 2007
TIME: 8:30 a.m.
PLACE: Central Valley Regional Water Quality Control Board
11020 Sun Center Drive, #200
Rancho Cordova, CA 95670-6114

Known designated parties for this hearing are as follows:

- Staff of the Regional Board
- Grizzly Lake Resort Improvement District
- California Sportfishing Protection Alliance

Only designated parties will have these rights: to call and examine witnesses; to introduce exhibits; to cross-examine opposing witnesses; to impeach any witness; and to rebut the evidence against him or her. All other persons wishing to testify or provide comments are interested persons and not designated parties. Such interested persons may request status as a designated party for purposes of this hearing by submitting such request in writing to the Regional Board no later than **8 March 2007**. The request must explain the basis for status as a designated party and in particular how the person is directly affected by the discharge.

All designated parties and interested persons may speak at the Regional Board meeting, and are expected to orally summarize their written submittals. Oral testimony and cross-examination will be limited in time by the Regional Board Chair.

The procedures governing Regional Board meetings may be found at Title 23, California Code of Regulations, Section 647 et seq. and are available upon request. Hearings before the Regional Board are not conducted pursuant to Government Code section 11500 et seq. The procedures may be obtained by accessing http://www.waterboards.ca.gov/water_laws/index.html. Information on meeting and hearing procedures is also available on the Regional Board's website at http://www.waterboards.ca.gov/centralvalley/board_meetings/mtgprocd.html or by contacting any one of the Regional Board's offices. Questions regarding such procedures should be directed to Ms. Kiran Lanfranchi-Rizzardi at (916) 464-4839.

The hearing facilities will be accessible to persons with disabilities. Individuals requiring special accommodations are requested to contact Ms. Kiran Lanfranchi-Rizzardi at (916) 464-4839 at least 5 working days prior to the meeting. TTY users may contact the California Relay Service at 1-800-735-2929 or voice line at 1-800-735-2922.

NOTICE OF PUBLIC HEARING
GRIZZLY LAKE RESORT IMPROVEMENT DISTRICT
DELLEKER WASTEWATER TREATMENT PLANT
PLUMAS COUNTY

-3-

Please bring the above information to the attention of anyone you know who would be interested in this matter.

Original signed by

James C. Pedri, P.E.
Assistant Executive officer

RSD: sae
2/21/07